



TEST RESULTS

Microbiological	Highest Number of Positive Samples	MCL	MCLG	Likely Source of Contamination	Violations Present		
No Detected Results were Found in the Calendar Year of 2025							
Lead and Copper	Monitoring Period	90 th Percentile	Range	Unit	AL	Sites Over AL	Likely Source of Contamination
COPPER, FREE	2023 - 2025	1.0145	0.108 - 1.05	ppm	1.3	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
LEAD	2023 - 2025	0		ppb	15	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
ARSENIC	10/22/2025	4.5	4.5	ppb	10	0	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
BARIUM	1/9/2023	0.233	0.233	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
CHROMIUM	1/9/2023	4.06	4.06	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
FLUORIDE	1/9/2023	0.278	0.278	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.
NITRATE-NITRITE	11/4/2025	0.429	0.429	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits
Unregulated Water Quality Data	Collection Date	Highest Value	Range	Unit	Secondary MCL		
SULFATE	5/15/2023	33.6	33.6	mg/L	250		

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

Violation Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2025			
Uncorrected Significant Deficiencies	Facility	Category Code	Category Description
04/09/2022	WATER SYSTEM	2247	22-004 Item 7e - Failure to require cross-connection surveys

The Buffalo Co SID 3 - Glenwood Estates has taken the following actions to address the deficiencies listed above:

There are no additional required health effects notices.
 There are no additional required health effects violation notices.

The Buffalo Co SID 3 - Glenwood Estates lead service line inventory has been prepared and can be accessed here: _____

